

***CITY OF LAREDO FIRE DEPARTMENT
FIRE INSPECTION REPORT***

Date: _____ Address: _____

Occupant: _____ Occupancy Type: _____

Inspection Type: _____ Occupancy phone number: _____

THE FOLLOWING VIOLATIONS WERE FOUND:

1. Accumulation of empty boxes, trash, rubbish, paper etc. IN ____ OUT _____ side of building.
2. Combustible items stored under stairs.
3. Merchandise crowded; obstructing aisles.
4. Objects blocking the EXIT egress.
5. EXIT doors blocked.
6. EXIT doors do not swing outward.
7. EXITS locked during business hours.
8. No EXITS and/or emergency lights. Need to install.
9. EXITS and/or emergency lights not working. Need repair.
10. Chemically treated dust mops and oily gas rags not stored in metal containers with lid.
11. Inadequate EXIT (s).
12. Lighting devices improperly installed.
13. Lighting devices too close to stock.
14. Junction boxes, light switches and electrical outlets do not have safety covers.
15. Need address on rear and/or front of building.
16. All permanent wiring and equipment not wired in conduit.
17. Ceiling tiles are missing.
18. Proper clearance from ceiling to stock not maintained. 12" minimum for non-sprinklered buildings.
19. Need 6" red-letter EXIT signs.
20. Daycares must have safety caps on all base plugs.
21. Gas lines must be tested by a licensed plumber.
22. Certificated of Occupancy not displayed.
23. Operating without a permit.
24. Need to maintain good housekeeping throughout building.
25. Electrical wiring was not to code. Must be checked by a licensed electrician.
26. Accumulation of grease on equipment.
27. Grease found on filters, ducts, and hood.
28. Hood over stove and deep fat fryers do not meet NFPA 96.
29. No automatic fire extinguishing system in accordance with NFPA 96. Install one.
30. Fire extinguishers need recharging.
31. Fire extinguishers have not been checked a licensed inspector on an annual basis.
32. Fire extinguishers are blocked.
33. No fire extinguisher in building, Required
34. Pressurized cylinders not anchored.
35. Sprinkler system requires inspection by a licensed contractor.

36. Access to sprinkler is blocked.
37. Fire department connections blocked.
38. Proper clearance from sprinkler heads to stock not maintained. Minimum of 18"
39. No smoke detectors as required.
40. Caps missing from connections.
41. Found illegal blocking of fire hydrant and/or parking in fire lane.
42. Bathroom door must not lock in Daycare.
43. Defective wiring.